

JDDZ.E4273 - CARTRIDGE FUSES, NONRENEWABLE

Cartridge Fuses, Nonrenewable

See General Information for Cartridge Fuses, Nonrenewable

COOPER BUSSMANN LLC
 114 OLD STATE RD
 ELLISVILLE, MO 63021 USA

E4273

Trademark and/or Tradename: "Brush", "Edison",



Nonrenewable cartridge fuses

Class	Cat. No. +	Interrupting Capacity		Fuse Rating	
		V ac	RMS Symmetrical Amps	V ac	Amps
J	DFJ	600Vac	200,000	600Vac	0 - 600
		450Vdc	100,000	450Vdc	15 - 600
RK5	ECN-R	250Vac	200,000	250Vac	0 - 600
RK5	ECS-R	600Vac	200,000	600Vac	0 - 600
CC	HCLR-R	600Vac	200,000	600Vac	0 - 30
J	JDL	600Vac	200,000	600Vac	1 - 600
		300Vdc	100,000	300Vdc	0 - 600
		375Vdc	100,000	375Vdc	70 - 100
L	LCL	600Vac	200,000	600Vac	601 - 4000
RK1	NCL-R	250Vac	200,000	250Vac	0 - 600
		250Vdc	100,000	250Vdc	70 - 350
H	NON	250Vac	10,000	250Vac	61 - 600
		125Vdc	10,000	125Vdc	61 - 100
H	NON (H)	250Vac	10,000	250Vac	0 - 60
		125Vdc	10,000	125Vdc	0 - 60
K5	NON (K5)	250Vac	50,000	250Vac	0 - 60
		125Vdc	50,000	125Vdc	0 - 60
H	NOS	600Vac	10,000	600Vac	61 - 600
H	NOS (H)	600Vac	10,000	600Vac	0 - 60

K5	NOS (K5)	600Vac	50,000	600Vac	0 - 60
----	-----------------	--------	--------	--------	--------

Nonrenewable cartridge fuses: current-limiting

Class	Cat. No. +	Interrupting Capacity		Fuse Rating	
		V ac	RMS Symmetrical Amps	V ac	Amps
CF	FCFxxxRN	600Vac	300,000	600Vac	1 - 60
		600Vac	200,000	600Vac	70 - 100
		600Vdc	50,000	600Vdc	1 - 100
J	JFL	600Vac	200,000	600Vac	0 - 600
T	JJN	300Vac	200,000	300Vac	0 - 1200
		160Vdc	20,000	160Vdc	15 - 600
		170Vdc	100,000	170Vdc	601 - 1200
T	JJN-xxxN	300Vac	200,000	300Vac	0 - 1200
		160Vdc	20,000	160Vdc	15 - 600
		170Vdc	20,000	170Vdc	601 - 1200
T	JJS	600Vac	200,000	600Vac	0 - 800
J	JKS	600Vac	200,000	600Vac	0 - 600
L	KLU	600Vac	200,000	600Vac	601 - 4000
L	KRP-C++	600Vac	300,000	600Vac	601 - 6000
		300Vdc	100,000	300Vdc	601 - 2000
		300Vdc	50,000	300Vdc	2501 - 3000
CC	KTK-R	600Vac	200,000	600Vac	0 - 30
		300Vdc	200,000	300Vdc	15 - 20
K1	KTN	250Vac	200,000	250Vac	61 - 600
RK1	KTN-R	250Vac	200,000	250Vac	0 - 600
		250Vdc	100,000	250Vdc	70 - 350
K1	KTS	600Vac	200,000	600Vac	61 - 600
RK1	KTS-R	600Vac	200,000	600Vac	0 - 600
L	KTU	600Vac	200,000	600Vac	601 - 6000
K1	KWN	250Vac	200,000	250Vac	0 - 600
RK1	KWN-R	250Vac	200,000	250Vac	61 - 400
		250Vdc	20,000	250Vdc	0 - 60
K1	KWS	600Vac	200,000	600Vac	0 - 600
RK1	KWS-R	600Vac	200,000	600Vac	0 - 600

		600Vdc	20,000	600Vdc	0 - 60
L	LCU	600Vac	200,000	600Vac	601 - 6000
T	LPT	600Vac	200,000	600Vac	35 - 60
K5	PON	250Vac	-	250Vac	15 - 60
T	TJN	300Vac	200,000	300Vac	0 - 1200
		160Vdc	20,000	160Vdc	15 - 600
		170Vdc	100,000	170Vdc	601 - 1200
T	TJS	600Vac	200,000	600Vac	0 - 800

Nonrenewable cartridge fuses: time delay, current-limiting

Class	Cat. No. +	Interrupting Capacity		Fuse Rating	
		V ac	RMS Symmetrical Amps	V ac	Amps
CC	ED-CC	300Vdc	20,000	300Vdc	0.5 - 2.8
		150Vdc	20,000	150Vdc	3 - 15
		300Vdc	20,000	300Vdc	20 - 30
		600Vac	200,000	600Vac	0.5 - 30
CC	FNQ-R	600Vac	200,000	600Vac	0.25 - 10
		600Vac	200,000	600Vac	12
		600Vac	200,000	600Vac	15 - 20
		600Vac	200,000	600Vac	25 - 30
		300Vdc	20,000	300Vdc	15 - 20
RK5	FRN-R	250Vac	200,000	250Vac	0 - 600
		125Vdc	20,000	125Vdc	0 - 60
		125Vdc	20,000	125Vdc	110 - 200
		250Vdc	20,000	250Vdc	201 - 600
RK5	FRN-R-ID	250Vac	200,000	250Vac	8 - 60
		125Vdc	20,000	125Vdc	8 - 60
RK5	FRS-R	600Vac	200,000	600Vac	0 - 600
		300Vdc	20,000	300Vdc	0 - 30
		250Vdc	20,000	250Vdc	31 - 60
		300Vdc	20,000	300Vdc	61 - 600
RK5	FRS-R-I	600Vac	200,000	600Vac	15 - 30
RK5	FRS-R-ID	300Vdc	20,000	300Vdc	0 - 30
		250Vdc	20,000	250Vdc	31 - 60

		600Vac	200,000	600Vac	0 - 60
CC	HCTR-R	600Vac	200,000	600Vac	0.25 - 10
		600Vac	200,000	600Vac	12
		600Vac	200,000	600Vac	15 - 20
		600Vac	200,000	600Vac	25 - 30
J	JHC	600Vac	200,000	600Vac	1 - 30
RK1	LEN-RK	250Vac	200,000	250Vac	0 - 600
RK1	LES-RK	600Vac	200,000	600Vac	70 - 600
		300Vdc	100,000	300Vdc	70 - 600
CC	LP-CC	300Vdc	20,000	300Vdc	0.5 - 2.8
		150Vdc	20,000	150Vdc	3 - 15
		300Vdc	20,000	300Vdc	20 - 30
		600Vac	200,000	600Vac	0.5 - 30
J	LPJ++	600Vac	300,000	600Vac	1 - 600
		300Vdc	100,000	300Vdc	0 - 600
J	LPJ-I++	600Vac	300,000	600Vac	1 - 600
		300Vdc	100,000	300Vdc	1 - 600
		375Vdc	100,000	375Vdc	70 - 100
RK1	LPN-RK++	250Vac	300,000	250Vac	0 - 600
		150Vdc	100,000	150Vdc	0 - 20
		125Vdc	100,000	125Vdc	25 - 60
		250Vdc	100,000	250Vdc	70 - 600
RK1	LPN-RK-I++	250Vac	300,000	250Vac	35 - 60
		125Vdc	100,000	125Vdc	35 - 60
RK1	LPN-RK-TP++	250Vac	300,000	250Vac	70 - 600
		250Vdc	100,000	250Vdc	70 - 600
RK1	LPS-RK++	600Vac	300,000	600Vac	0 - 600
		300Vdc	100,000	300Vdc	0 - 600
RK1	LPS-RK-I++	600Vac	300,000	600Vac	6 - 60
		300Vdc	100,000	300Vdc	6 - 60
RK1	LPS-RK-TP++	600Vac	300,000	600Vac	70 - 600
		300Vdc	100,000	300Vdc	70 - 600
G	SC	170Vdc	10,000	170Vdc	0 - 20

		300Vdc	10,000	300Vdc	25 - 30
		300Vdc	10,000	300Vdc	35 - 60
		600Vac	100,000	600Vac	0 - 20
		480Vac	100,000	480Vac	21 - 60
G	SEC	170Vdc	10,000	170Vdc	0 - 20
		300Vdc	10,000	300Vdc	25 - 30
		300Vdc	10,000	300Vdc	35 - 60
		600Vac	100,000	600Vac	0 - 20
		480Vac	100,000	480Vac	21 - 60
CF	TCFxxx	600Vac	300,000	600Vac	1 - 100
		300Vdc	100,000	300Vdc	1 - 100
CF	TCFxxxRN	600Vac	300,000	600Vac	1 - 100
		300Vdc	100,000	300Vdc	1 - 100

+ - Type numbers include suffix digits indicating ampere rating

++ - May be followed by SP.

[Click here to view the Colombia Market Access Certification](#)

Last Updated on 2018-11-27

The appearance of a company's name or product in this database does not in itself assure that products so identified have been manufactured under UL's Follow-Up Service. Only those products bearing the UL Mark should be considered to be Certified and covered under UL's Follow-Up Service. Always look for the Mark on the product.

UL permits the reproduction of the material contained in the Online Certification Directory subject to the following conditions: 1. The Guide Information, Assemblies, Constructions, Designs, Systems, and/or Certifications (files) must be presented in their entirety and in a non-misleading manner, without any manipulation of the data (or drawings). 2. The statement "Reprinted from the Online Certifications Directory with permission from UL" must appear adjacent to the extracted material. In addition, the reprinted material must include a copyright notice in the following format: "© 2019 UL LLC"